

1.0 **GENERAL**

1.1 **Coordination Requirements**

- .1 UBC Infrastructure Development, Transition Team for Maintenance information.

1.2 **Description**

- .1 Cranes and Hoists.

2.0 **DESIGN REQUIREMENTS**

2.1 **General**

1. Equipment design and installation requires full compliance with all applicable regulatory bodies including:
 1. Worksafe BC
 2. CSA B167-96
 3. ASME B30.2-2001
2. Each crane and hoist shall have a separate disconnect switch capable of being locked in the open position. The switch shall be horsepower rated and capable of interrupting the locked rotor current of the crane or hoist motor.

*****END OF SECTION*****