


NOTES:

1. REFER TO SECTION 27 40 00 - 2.6 FOR SPECIFIC REQUIREMENTS.
2. ESTIMATED HEAT GAIN OF 4000 BTU/H FOR EACH PROJECTOR AND EACH RACK FOR A TOTAL OF 20000 BTU/H.



INFORMATION TECHNOLOGY
Audio Visual Services
 THE UNIVERSITY OF BRITISH COLUMBIA
 INFORMATION TECHNOLOGY
 AUDIO VISUAL SERVICES
 B32 - 2194 HEALTH SCIENCES MALL
 VANCOUVER BC CANADA V6T 1Z3
 T 604.822.8155 F 604.822.2004

1	APR 01, 2021	CREATION
NO	DATE	REVISIONS

UBC TECHNICAL GUIDELINES
DIVISION 27
UBC IT AV

TYPICAL PROJECTION BOOTH			
AVSK-11			
DRAWN	SCALE	PROJECT #	DATE
GS	N.T.S.		APRIL 01, 2021