



**NOTES:**

1. THIS DRAWING REPRESENTS THE UTP TERMINAL LAYOUT IN A TYPICAL COMMUNICATIONS ROOM AND IS NOT TO BE TAKEN AS THE FINAL DESIGN.
2. ALL BIX RINGS MUST BE INSTALLED REGARDLESS OF BIX FRAME PRESENCE
3. HANG LIGHTS ON CHAIN TO ALLOW FOR FREE SWING ABOVE THE FLEX TRAY.
4. MOUNT GROUNDING BUS BAR AND POWER OUTLETS @ 300 mm AFF' MEASURED FROM THE TOP OF THE DEVICES.
5. 300mm OR MOUNTING HEIGHT TO MATCH EXISTING OUTLET MOUNTING HEIGHT IN THE SAME ROOM.
6. NO OUTLETS OR DEVICES WILL BE AFFIXED TO THE PLYWOOD SHEATHING WITHOUT UBC IT APPROVAL
7. CABLE ROUTING PATHS TAKE PRIORITY OVER DEVICE AND OUTLET POSITIONING

				Building/Facility Name	
No.	BY	DATE	REVISIONS	App'd	
Scale		NONE		BY	DATE
Sheet No.		1 of 1		Drawn	MET 05 MAR 04
UBC Project No.				Check'd	TZ 5 FEB 14
				Design'd	
				Approv'd	B. MACDONALD-RCDD 15 FEB 14
				<b>COMMUNICATIONS MAIN COMMUNICATION ROOM UTP TERMINAL (TYPICAL)</b>	
				<b>UNIVERSITY OF BRITISH COLUMBIA</b>	
				File No.	ITSTD-06
This drawing and its contents are confidential, and are for the private information of the Client Name. It is not to be relied upon or used in whole or in part for other purposes or by or for the benefit of others without prior adaptation and specific written verification by UBC, Information Technology.				Rev.	0