

NOTES:

MINIMUM ONE PATCH PANEL SHALL BE INSTALLED WHEN INSTALLING AN EQUIPMENT RACK IN A COMMUNICATIONS ROOM. PROVIDE ADDITIONAL PATCH PANEL AS REQUIRED

FINAL DETAILS ARE DETERMINED AT TIME OF INSTALLATION WITH UBC CONNECTIVITY SERVICES.

INSTALL ADDITIONAL RACK WHEN MORE TERMINATION SPACE THEN SHOWN IS NEEDED.

							Building/Facility Name		
							-		
No.	BY DATE REVISIONS			IS	App'd				
Scale NONE					BY	DATE	COMMUNICATIONS		
Sheet No.				Drawn	MET	05 MAR 04	COMMUNICATIONS		
1 of 1			of	Check'd	TZ	5 FEB 14]		
UBC Project No.				Design'd			TYPICAL EQUIPMENT PLACEM	FNT	
				Approv'd	B. Macdonald-RCDD	15 FEB 14	THICAL EQUITMENT TEACEMENT		
This drawing and it's contents are confidential, and are for the private information of the Client Name It is not to be relied upon or used in whole or in part for other purposes or by or for the benefit						UNIVERSITY OF BRITISH COLUMBIA			
Technology It is not to be relied upon or used in whole of part for other purposes or by or for the bene of others without prior adaptation and specific written verification by UBC, Information Technology					but prior adaptation tion by UBC, Informa	and specific tion Technolog	ITSTD-15	Rev.	