



NOTES:

MINIMUM CONDUIT SIZE SHALL BE 27mm. 27mm FEEDER CONDUIT SHALL SUPPLY CABLE TO A MAXIMUM OF TWO OUTLETS. IF A LARGER NUMBER OF OUTLETS HAS TO BE INSTALLED IN THE SAME AREA, A MINIMUM 50mm CONDUIT SHALL BE USED AS A "ZONE CONDUIT" FOR EACH AREA. THE CONDUIT SHALL TERMINATE IN A LARGE PULL-BOX INSIDE THE AREA WHICH SHALL BE THE CONDUIT DISTRIBUTION POINT FOR THAT AREA.

OUTLET BOX: DUAL GANG DEEP (MDB2).

				Building/Facility Name	
No.	BY	DATE	REVISIONS	App'd	
Scale		NONE		BY	DATE
Sheet No.		1 of 1		Drawn	MET 05 MAR 04
UBC Project No.				Check'd	TZ 5 FEB 14
				Design'd	
				Approv'd	B. MACDONALD-RCDD 15 FEB 14
				COMMUNICATION RISER & PATHWAYS IN ACADEMIC BUILDING (TYPICAL)	
		This drawing and its contents are confidential, and are for the private information of the Client Name. It is not to be relied upon or used in whole or in part for other purposes or by or for the benefit of others without prior adaptation and specific written verification by UBC, Information Technology.		UNIVERSITY OF BRITISH COLUMBIA	
				File No.	ITSTD-19