

IF RISER COPPER CABLES ARE INSTALLED PROVIDE PURPLE ICON FOR EACH CAT 6A BB CABLE GROUP. LABEL FRONT PANEL LOCAL COMM ROOM TO DESTINATION COMM ROOM WITH PORT NUMBERS eg.001 Rmxxx Port 1-6 TO 011 RmxxxPort 1-6

ADD LETTER DESIGNATIONS ON PATCH PANELS (TYP.) FIRST PATCH PANEL STARTS AT "P1", THEN "P2" SEQUENTIALLY.

MACHINE PRINTED ON MYLAR LABEL BOTH ENDS OF CABLES.

CCT001235 011-P1-01

P1

# 24 PORT PATCH PANEL

BLANK, NO LABELLING REQUIRED ON PATCH PANEL OUTLETS

Building/Facility Name

| No. | BY | DATE | REVISIONS | App'd |
|-----|----|------|-----------|-------|
|     |    |      |           |       |

|           |        |          |                             |
|-----------|--------|----------|-----------------------------|
| Scale     | NONE   | BY       | DATE                        |
| Sheet No. | 1 of 1 | Drawn    | MET 05 MAR 04               |
|           |        | Check'd  | TZ 5 FEB 14                 |
|           |        | Design'd |                             |
|           |        | Approv'd | B. MACDONALD-RCDD 15 FEB 14 |

## COMMUNICATIONS UTP 24 PORT PATCH PANEL



This drawing and its contents are confidential, and are for the private information of the Client Name. It is not to be relied upon or used in whole or in part for other purposes or by or for the benefit of others without prior adaptation and specific written verification by UBC, Information Technology.



UNIVERSITY OF BRITISH COLUMBIA

|          |          |      |   |
|----------|----------|------|---|
| File No. | ITSTD-65 | Rev. | 0 |
|----------|----------|------|---|