



NOTE:

1. THE DRAWING SHOWS TYPICAL REQUIREMENTS WHEN CONNECTING FIRE ALARMS, CLOCK & BELL CIRCUITS, BMS CIRCUITS, ELEVATOR PHONES, SECURITY ALARM, ACCESS CONTROL SERVICES & HYDRO UTILITY METERS TO THE COMMUNICATIONS SYSTEM.
2. FINAL DETAILS WILL BE CONFIRMED WITH UBC IT SERVICES REPRESENTATIVE AT TIME OF INSTALLATION.
3. QUANTITY OF CABLES DEPENDS ON APPLICATION, MIN 1X4 PR CAT 6A PER SYSTEM. ALL CABLING TO TERMINATE IN DEMARCTION BOX. CABLE USAGE WILL BE DETERMINED BY SYSTEM – VOICE, DATA OR BOTH.
4. FACEPLATES ARE NOT TO BE USED, USE BLANK BOX COVER

Sheet No.

1 of 1

	BY	DATE
Drawn	DE	SEPT 2025
Checked		
Design'd	TZ	SEPT 2025
Approved	EB	SEPT 2025

DEMARCATION FOR  
SPECIAL SERVICES (TYPICAL)

File No.

ITSTD-22

Rev.

0

