

IF RISER COPPER CABLES ARE INSTALLED PROVIDE
PURPLE ICON FOR EACH CAT 6A BB CABLE GROUP.
LABEL FRONT PANEL
LOCAL COMM ROOM TO DESTINATION COMM ROOM
WITH PORT NUMBERS
eg.001 Rmxxx Port 1-6 TO 011 RmxxxPort 1-6

ADD LETTER DESIGNATIONS ON
PATCH PANELS (TYP.) FIRST
PATCH PANEL STARTS AT "P1",
THEN "P2" SEQUENTIALLY.

MACHINE PRINTED ON MYLAR
LABEL BOTH ENDS OF CABLES.

CCT001235 011-P1-01

24 PORT PATCH PANEL

BLANK, NO LABELLING
REQUIRED ON PATCH
PANEL OUTLETS

Sheet No.

1 of 1

	BY	DATE
Drawn	DE	SEPT 2025
Checked		
Design'd	TZ	SEPT 2025
Approved	EB	SEPT 2025

UTP 24
PORT PATCH PANEL



THE UNIVERSITY OF BRITISH COLUMBIA
Information Technology

File No.

ITSTD-65

Rev.

0